



AGENDA
STATE FIRE MARSHAL
FIRE ALARM ADVISORY COMMITTEE

Wednesday, May 8, 2019
10:00 A.M. – 1:00 P.M. (PST)

Office of the State Fire Marshal
2251 Harvard Street, 1st Floor
Redwood Conference Room
Sacramento, CA 95815

Teleconference Number
(605) 472-5773
Participant Code
754391#

- | | | |
|------|---|-------------|
| I. | <u>CALL TO ORDER</u> | David |
| II. | <u>ROLL CALL and INTRODUCTIONS</u> | David |
| III. | <u>OLD BUSINESS</u> | |
| | • Visual notification in Private/Common offices and in undefined rooms or area such as Phone rooms, Wellness rooms, etc. | Sagiv, Rick |
| | • Visual notification in Hearing-Impaired sleeping rooms in R-1, R-2 occupancies – Could it be done with a CSFM listed 120VAC Smoke-Strobe Combination device with battery backup only for the smoke-alarm portion? | Sagiv |
| | • Update on the CSFM Task-Group on Elevators | Sagiv |
| | • Licensing requirements for testing and inspection | Jay |
| IV. | <u>NEW BUSINESS</u> | |
| | • Should a proposal be submitted during the Intervening Code Cycle that will require ERRC systems to be listed as complying with UL 2524? | Richard |
| | • Could addressable system smoke detectors with integral High-Frequency sounder bases be used in sleeping rooms of R occupancies in lieu of high-frequency smoke alarms ? | Sagiv |

- If an EVACS is installed voluntarily in a Low-Rise R-2 occupancy, is it required to generate Pre-recorded messages via the speakers or a Temporal-3 LF tone is sufficient?
- Can a Wireless communicator (Cellular or RF) or an IP DACT be used solely as a single technology for transmitting off-site FA signals to the approved supervising station?
- Is a 2-Way ECS call box required to transmit the exact location within the building to the off-site supervising station? Must this supervising station comply with NFPA 72 Chapter 26 (Central, Remote or proprietary station)?

Sagiv and Rick

Sagiv

V. **OPEN FORUM**

VI. **NEXT MEETING**