



California State Fire Marshal Information Bulletin 18-003

Issued: March 20, 2018

Errata for California Building Code

CBC Table 705.2

The California Building Code Table 705.2 was printed without the fourth row. It should match the International Building Code as shown:

TABLE 705.2
MINIMUM DISTANCE OF PROJECTION

FIRE SEPARATION DISTANCE (FSD)	MINIMUM DISTANCE FROM LINE USED TO DETERMINE FSD
0 feet to 2 feet	Projections not permitted
Greater than 2 feet to 3 feet	24 inches
Greater than 3 feet to less than 30 feet	24 inches plus 8 inches for every foot of FSD beyond 3 feet or fraction thereof
30 feet or greater	20 feet

CBC Table 506.2 for R-2.1

Table 506.2 was printed with errors for the R-2.1 occupancy. It should read as follows:

Table 506.2

OCCUPANCY CLASSIFICATION	TYPE OF CONSTRUCTION									
	SEE FOOTNOTES	TYPE I		TYPE II		TYPE III		TYPE IV	TYPE V	
		A	B	A	B	A	B	HT	A	B
<i>R-2.1^b</i>	<i>NS^d</i>	<i>UL</i>	<i>55,000</i>	<i>19,000</i>	<i>NP</i>	<i>16,500</i>	<i>NP</i>	<i>NP</i>	<i>10,500</i>	<i>NP</i>
	<i>S13R</i>	<i>UL</i>	<i>220,000</i>	<i>76,000</i>	<i>NP</i>	<i>66,000</i>	<i>NP</i>	<i>NP</i>	<i>42,000</i>	<i>NP</i>
	<i>S1</i>	<i>UL</i>	<i>165,000</i>	<i>57,000</i>	<i>NP</i>	<i>49,500</i>	<i>NP</i>	<i>NP</i>	<i>31,500</i>	<i>NP</i>
	<i>SM (without height increase)</i>	<i>UL</i>	<i>55,000</i>	<i>19,000</i>	<i>NP</i>	<i>16,500</i>	<i>NP</i>	<i>NP</i>	<i>10,500</i>	<i>NP</i>
	<i>SM (with height increase)</i>	<i>UL</i>	<i>55,000</i>	<i>19,000</i>	<i>NP</i>	<i>16,500</i>	<i>NP</i>	<i>NP</i>	<i>10,500</i>	<i>NP</i>