



# CAL FIRE - OFFICE OF THE STATE FIRE MARSHAL

## Information Bulletin 25-002

---

Issued: February 25, 2025

### Consumer Product Recall

#### Three61 Recalls Samurai Mini Smoke Alarms

**NAME OF PRODUCT:**

Three61 Samurai Mini Smoke Alarms, Model Number SM1

**RECALL DATE:**

January 16, 2025

**UNITS:**

About 328,000

**DESCRIPTION:**

Three61 recalled their Samurai-branded Mini Smoke Alarms with model number SM1. The smoke alarms are not listed by the California Office of the State Fire Marshal (OSFM), and as a result, shall not be marketed, distributed, offered for sale, or sold in California per Health and Safety Code 13114(b)(1). The smoke alarms were sold in packs of two or three alarms and came with lithium-ion batteries, adhesive stickers, screws, mounting plates and an instruction manual. The white and silver plastic smoke alarms measure about 2.5 by 2.5 by 2.5 inches. “Smoke” appears on the front of the alarm below a button and “installed on” on the back. The model number is located on the product packaging.

**HAZARD:**

The smoke alarms can malfunction and fail to alert consumers of a fire, posing a risk of smoke inhalation or death. Smoke sensitivity tests performed on the alarms by Consumer Product Safety Commission (CPSC) found that one of the detectors that was tested failed to alert when exposed to pre-determined concentrations of smoke.

**REMEDY:**

For California residents, consumers should immediately replace the Three61 Samurai-branded Mini Smoke Alarms model number SM1 with an OSFM listed smoke alarm. Smoke alarms approved in California can be found at the OSFM Building Materials Listing Program’s website: <https://calfire.govmotus.org/BMLSearch/Index>.

For residents outside of California, consumers should immediately contact Three61 and visit their recall website at [www.samuraibrands.com/recall](http://www.samuraibrands.com/recall).



# CAL FIRE - OFFICE OF THE STATE FIRE MARSHAL

## Information Bulletin 25-002

**Note:** Recalled lithium-ion batteries should be disposed of in accordance with any local and state ordinances, following the procedures established by your municipal recycling center for damaged/defective/recalled lithium batteries, because these potentially hazardous batteries must be handled differently than other batteries. Do not throw this recalled battery in the trash. Do not deposit this recalled battery in used battery recycling boxes found at various retail and home improvement stores.

### **INCIDENTS/INJURIES:**

Three61 has received eight reports of the alarms failing to activate in the presence of smoke. No injuries have been reported.

### **SOLD AT:**

Through HSN nationwide and online at HSN.com from July 2020 through November 2024 for between \$40 and \$50, depending on the amount purchased.

### **MANUFACTURER(S):**

China

### **CONSUMER PRODUCT SAFETY COMMISSION (CPSC) RECALL NUMBER:**

25-095

For more information visit the following website(s):

<https://www.cpsc.gov/Recalls/2025/Three61-Recalls-Samurai-Mini-Smoke-Alarms-Due-to-Failure-to-Alert-Consumers-to-a-Fire-Sold-Exclusively-by-HSN>

<https://www.samuraibrands.com/recall>

### **PICTURE OF RECALLED SAMURAI-BRANDED MINI SMOKE ALARMS**

