



CAL FIRE - OFFICE OF THE STATE FIRE MARSHAL

Information Bulletin 25-007

Issued: August 11, 2025

Consumer Product Recall

Apollo America Recalls Combination Smoke and Carbon Monoxide (CO) Detectors

NAME OF PRODUCT:

Apollo America 51000-600 Combination Smoke and Carbon Monoxide Detectors

RECALL DATE:

June 5, 2025

UNITS:

About 50,000

DESCRIPTION:

Apollo America recalled their Model 51000-600 Combination Smoke and CO Detectors (California Office of the State Fire Marshal Listing 7275-1004:0502). The recalled detector was sold in a white color. The front of the recalled detectors has the text "Replace by" followed by a date ranging from 2034/June to 2034/October. "Apollo" and the model number 51000-600 are on the back of the detector. The manufactured date of the detector can also be found on the back. The detector will have a 10-year lifespan from the manufactured date.

HAZARD:

Due to an issue identified by Vivint in the firmware causing connectivity issues, the recalled detectors can malfunction and fail to alert consumers of a fire or carbon monoxide (CO) leak, posing a risk of smoke inhalation, carbon monoxide poisoning or death.

REMEDY:

Vivint is sending a free replacement detector to all known purchasers. Consumers should continue using the recalled detectors until they install the replacement detector. Consumers should install the replacement detector immediately upon receipt. Detailed instructions on how to remove the recalled detector and install the replacement can be found on Vivint's website, linked below. Consumers should contact Vivint with questions about whether their detector is included in this recall or the status of their replacement detector. Once the replacement detector is installed, consumers should write "recalled" on the original product, remove the batteries, dispose of the detector in their household garbage, and dispose of the batteries in accordance with local and state regulations. Apollo America has already corrected the issue



CAL FIRE - OFFICE OF THE STATE FIRE MARSHAL

Information Bulletin 25-007

with the product, new devices have been recertified with a firmware solution, and this device will continue to be listed by the California Office of the State Fire Marshal.

Note: If you choose to dispose of the detector's primary/non-rechargeable lithium battery, do not throw the battery in the trash, or in the general recycling stream (e.g., street-level or curbside recycling bins). Lithium batteries must be disposed of differently than other batteries, because they present a greater risk of fire. Your municipal household hazardous waste (HHW) collection center or battery recycling boxes found at various retail and home improvement stores may accept this lithium battery for disposal. Before taking your battery to a HHW collection center, contact that office ahead of time and ask whether it accepts lithium batteries. If it does not, contact your municipality for further guidance.

INCIDENTS/INJURIES:

None reported

SOLD AT:

Online at www.Vivint.com and via door-to-door and telephone sales by Vivint from June 2024 through October 2024 for between \$50 and \$100.

MANUFACTURER(S):

Apollo America Inc., of Auburn Hills, Michigan

CONSUMER PRODUCT SAFETY COMMISSION (CPSC) RECALL NUMBER:

25-322

For more information visit the following website(s):

[Apollo America Recalls Combination Smoke and Carbon Monoxide \(CO\) Detectors Due to Failure to Alert Consumers to a Fire or Carbon Monoxide Leak; Risk of Serious Injury or Death; Sold Exclusively by Vivint | CPSC.gov](#)

[Combo Smoke and CO Detector \(SMKCO1\) - Replacement Guide](#)



CAL FIRE - OFFICE OF THE STATE FIRE MARSHAL

Information Bulletin 25-007

PICTURES OF RECALLED DEVICE

