



California State Fire Marshal Information Bulletin 15-001

June 26, 2015

Kidde ABC and BC-rated Fire Extinguishers Recall

Walter Kidde Portable Equipment Inc. ("Kidde") in conjunction with the U.S. Consumer Product Safety Commission (CPSC) announced a voluntary recall to replace certain Kidde black plastic Zytel® nylon valve disposable fire extinguishers. Kidde has sent copies to their retail customers with instructions to post a copy of the safety notice in stores that sold these extinguishers.

Safety Hazard: A faulty valve component can cause the disposable fire extinguishers not to fully discharge when the lever is repeatedly pressed and released during a fire emergency, posing a risk of injury.

The Office of the State Fire Marshal sees this as a serious safety hazard to well-being of the citizens of California and therefore, the portable fire extinguishers models listed below should be replaced.

This recall involves Kidde ABC and BC-rated fire extinguishers models listed below, that were manufactured between July 23, 2013 and October 15, 2014 and sold between August 2013 and November 2014.

FX340SC	RESSP	FC110
FX340GW	Mariner 5 G	FX10
2A10BC	Mariner 5	FX210R
FA10G	FA5B	5BCW
FA110	FX5II	5BC
Mariner 110	FC5	1A 10BC
Mariner 10	FX210	10BC
FX10BC	KFH Twin	1A 10BCW
FX10K	M110 Twin	FH/RESSP
FC10	M5 Twin	XL 5MR
FX210W	FA5B	

For additional questions, please direct them to Kidde at 1-855-283-7991 or www.kidde.com to determine whether your extinguishers are affected or the CPSC website at <http://www.cpsc.gov/en/Recalls/2015/Kidde-Disposable-Plastic-Fire-Extinguishers/>