



## California State Fire Marshal **CODE INTERPRETATION**

Date Issued	September 7, 2016	Interpretation	16-005
Topic	Private Development (campus) Fire Pump		
Code Section(s)	2013 editions of NFPA 13, 20, and 24		
Requested by	Advanced Automatic Sprinkler, Inc. Fred Benn, President		
Date Received	July 28, 2016		

**Question 1:** Can a single fire pump supply water to multiple buildings if the buildings are all on the same property with one owner?

**Answer 1: Yes.** If a private development (campus) needs a fire protection pump, this is typically accomplished by installing a dedicated fire pump (in accordance with NFPA 20) in parallel with a domestic pump or as part of a dedicated fire branch/loop off a water supply.

**Question 2:** If yes to Question 1, is the fire pump sized for a single fire occurring at one time as stated in the 2013 edition of NFPA 13 Section 1.1.3 or must the pump be sized for fires occurring in all buildings at the same time?

**Answer 2:** The fire pump is sized for a single fire area. As long as the greatest single demand of any of the fire protection systems that the fire pump serves is met by the fire pump, the plans are acceptable.