4-2a: Replace a Burst Section of Hose

Candidate Information
Candidate Name and SFT ID Number:
Circle One: Day 1 First Attempt / Day 1 Second Attempt / Day 2 First Attempt / Day 2 Second Attempt
General Information
NFPA Standard: 1001 (2019), JPR 4.3.10, 4.5.2 / **CTS Guide:** 4-2 / **Course Plan:** Fire Fighter 1A, Topic 5-5
Performance Outcome: Replace a burst or damaged hose section to ensure the hose is clamped, the burst section is removed, a new section is placed in its spot, the hose clamp is removed, and the hose line is ready for operation.
Candidate Directions: You will replace a simulated burst section of hose. The test will begin when I say, "start." The test will end when you say, "done." Do you understand the directions?

Performance Measures (check appropriate box) The candidate must complete all steps (100%) to receive a passing score.	**Pass**	**Fail**
1. Wears and uses appropriate PPE/SCBA/equipment at all times during evaluation		
2. Places hose clamp at least five feet behind the female coupling of damaged hose length		
3. Applies hose clamp correctly		
4. Directs team member to drain, or drains, hose at nozzle		
5. Removes damaged hose section		
6. Replaces damaged hose section of hose with new hose		
7. Closes nozzle		
8. Releases the clamp slowly and correctly to prevent water hammer		

Evaluation Results
Overall Evaluation: Pass / Fail (circle one)
Student Signature / Date:
Print Student Name:
Evaluator Signature / Date:
Print Evaluator Name:
Comments: