3-10a: Operate a Charged Attack Hose Line from a Ground Ladder

Candidate Information
Candidate Name and SFT ID Number:
Circle One: Day 1 First Attempt / Day 1 Second Attempt / Day 2 First Attempt / Day 2 Second Attempt
General Information
NFPA Standard: 1001 (2019), JPR 4.3.10 / **CTS Guide:** 3-10 / **Course Plan:** Fire Fighter 1A, Topic 5-9 and 5-12
Performance Outcome: Operate an attack hose line from a ground ladder.
Candidate Directions: You will work with a team member to secure yourself and an attack hose to an in-place ground ladder and operate the hose into the opening. The evolution will begin when I say, "start." The evolution will end when you have returned all equipment to a ready state and say, "done." Do you understand the directions?

Performance Measures (check appropriate box) The candidate must complete all steps (100%) to receive a passing score.	Pass	Fail
1. Wears and uses appropriate PPE/SCBA/equipment at all times during evaluation		
2. Climbs ladder with uncharged attack hose line and positions on ladder to operate nozzle into opening		
3. Locks into the ladder using log lock method or safety harness		
4. Places nozzle through ladder rung, extending the hose at least one foot in front of their body		
5. Ties off attack hose with approved method		
6. Calls for water		
7. Secures hose slack		
8. Operates nozzle, opening and closing slowly to prevent water hammer (Nozzle can be operated between or outside of ladder rungs.)		

Evaluation Results
Overall Evaluation: Pass / Fail (circle one)
Student Signature / Date:
Print Student Name:
Evaluator Signature / Date:
Print Evaluator Name:
Comments: